




America

CERTIFICATE

No. U10 112882 0007 Rev. 00

Holder of Certificate: CONVERDAN A/S
Aage Grams Vej 6
6500 Vojens
DENMARK

Certification Mark:



Product: Power supply

Model(s): DC/DC Converter CDC150HV-24

Parameters:

Rated voltage:	600 – 950 VDC
Rated current:	1.5 A
Rated Output voltage:	24 VDC
Rated Output current:	28 A
Protection class:	I

Tested according to: UL 61010-1:2012/R:2019-07
CSA C22.2 No. 61010-1:2012/A1:2018-11
UL 61010-2-201:2018
CSA C22.2 No. 61010-2-201:2018

This product was voluntarily tested to the relevant safety requirements referenced on this certificate. It can be marked with the certification mark above. The mark must not be altered in any way. The certificate holder shall not transfer this certificate to third parties. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing and Certification Regulations". For Canadian standards TÜV SÜD America Inc. is accredited by the Standards Council of Canada to ISO/IEC 17065.

Test report no.: 713223000

Date, 2022-04-11

(Abdul Sabbagh)